



4/26/2017

Attn: Mr. Marshall Green
Quick Mount PV
2700 Mitchell Dr.
Walnut Creek, CA, 94598

RE: Quick Mount PV QBlock Mount System for use with
SnapNrack Series 100 Roof Mount System

SEI Project No.: 17054.00

Dear Mr. Green

Structural Enginuity Inc. (SEI) has completed its review of the Quickmount PV QBlock Mount System for use in conjunction with the SnapNrack Series 100 Roof Mount System 6063 Alloy Rails. The QBlock product line includes the E-Mount (QMSE), E-Mount Lag (QMSE-LAG), Classic Composition Mount (QMSC), and the Classic Shake Mount (QMLC).

The review was based on the following reference data:

- SnapNrack, Series 100 Residential Roof Mount System Installation Manual
- Norman Scheel, Structural Report and Calculations for Series 100 Roof Mount, July 6, 2013
- Applied Materials & Engineering, Quick Mount PV Load Testing, Project Number 108443C, May 22, 2009
- Applied Materials & Engineering, Quick Mount PV Load Testing, Project Number 108443C, May 22, 2009
- Applied Materials & Engineering, Laboratory Load Testing of the QMSE-Lag, Project Number 114490C, October 29, 2014
- ICC Evaluation Service, Quick Mount PV Roof Mounts, ESR-2835, April 2015
- ICC Evaluation Service, Quick Mount PV Roof Mounts, ESR-3744, November 2016

SEI has determined that the QMSE, QMSE-Lag, QMSC, and QMLC mounts are suitable for use with the SnapNrack Series 100 Roof Mount System, 6063 Alloy Rails. The approved installation and allowable loads for the Quick Mount PV QBlock products is outlined in the ICC reports (ESR-2835 & ESR-3744). These values are shown below, no additional load duration factors may be applied to these values.

Table 1: QMSE, QMSC, & QMLC Roof Mounts

Load Direction	Specific Gravity of Lumber Rafter	Allowable Load
Uplift	0.5	811
	0.36	436
Lateral	0.5	671
	0.36	634


Table 2: QMSE-LAG Roof Mount

Load Direction	Specific Gravity of Lumber Rafter	Allowable Load
Uplift	0.5	732
	-	-
Lateral	0.5	526
	-	-

SEI has prepared allowable rail span charts for the Series 100 Roof Mount System used in conjunction with the Quick Mount PV QBlock products. These span tables serve as a quick reference for looking up maximum rail spans based on building and site conditions and follow the 2016 CBC, 2015 IBC/IRC and applicable ASCE 7-10 load cases. The tables take into account the strength of the rail system as well as the allowable uplift and lateral forces of the QBlock mounts. A site specific analysis is required if the site conditions or building characteristics do not meet the requirements listed in the attached tables. In all cases, the tables are meant to be used in conjunction with SnapNrack Series 100 Structural Report and Calculations and all requirements listed are still applicable for these tables including edge zones and edge distances.

Please contact our office if you have any further questions relating to this matter.

Sincerely,



Peter Martin
Engineer II
pmartin@structuralenginuityinc.com



Allan T. Myket, P.E.
President/Founder
amyket@structuralenginuityinc.com



4/26/17

Structural Enginuity Inc.

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE, QMSC, QMLC Products

Table 1A		Roof Height: 0-30 ft				Rafter Species: Douglas Fir				Roof Angle: 8 - 26 degrees				Specific Gravity: 0.50			
Wind Load (Exposure Category B)																	
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190		
	qh	11.06	12.09	13.16	14.28	15.45	16.66	17.91	19.22	20.56	21.96	23.4	26.41	29.61	32.99		
	pg	ps	-7.63	-8.34	-9.08	-9.85	-10.7	-11.5	-12.4	-13.3	-14.2	-15.2	-16.1	-18.2	-20.4	-22.8	
	0	0	126	126	126	126	126	123	117	112	107	103	99	93	87	81	
	10	7.315	125	125	125	125	125	123	117	112	107	103	99	93	87	81	
	20	14.63	98	98	98	98	98	98	98	98	98	98	98	98	93	87	81
	30	21.95	83	83	83	83	83	83	83	83	83	83	83	83	83	83	81
	40	29.26	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73
	50	36.58	66	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	60	43.89	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61
	70	51.21	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57
	80	58.52	54	54	54	54	54	54	54	54	54	54	54	54	54	54	54
	100	73.15	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48
	120	87.78	44	44	44	44	44	44	44	44	44	44	44	44	44	44	44

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE, QMSC, QMLC Products

Table 1B		Roof Height: 0-30 ft				Rafter Species: Western Cedar				Roof Angle: 8 - 26 degrees				Specific Gravity: 0.36			
Wind Load (Exposure Category B)																	
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190		
	qh	11.1	12.1	13.2	14.3	15.4	16.7	17.9	19.2	20.6	22.0	23.4	26.4	29.6	33.0		
	pg	ps	-7.6	-8.3	-9.1	-9.9	-10.7	-11.5	-12.4	-13.3	-14.2	-15.2	-16.1	-18.2	-20.4	-22.8	
	0	0	126	126	126	126	126	123	117	112	107	103	99	93	87	81	
	10	7.315	125	125	125	125	125	123	117	112	107	103	99	93	87	81	
	20	14.63	98	98	98	98	98	98	98	98	98	98	98	93	87	81	
	30	21.95	83	83	83	83	83	83	83	83	83	83	83	83	83	81	
	40	29.26	73	73	73	73	73	73	73	73	73	73	73	73	73	73	
	50	36.58	66	66	66	66	66	66	66	66	66	66	66	66	66	66	
	60	43.89	61	61	61	61	61	61	61	61	61	61	61	61	61	61	
	70	51.21	57	57	57	57	57	57	57	57	57	57	57	57	57	57	
	80	58.52	54	54	54	54	54	54	54	54	54	54	54	54	54	54	
	100	73.15	48	48	48	48	48	48	48	48	48	48	48	48	48	48	
	120	87.78	44	44	44	44	44	44	44	44	44	44	44	44	44	44	

Notes:

1. Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and allowable uplift and lateral values of Quick Mount products per ICC reports.
2. Edge zone reductions are only required at shaded spans where reduction is 29 inches to a minimum of 32 inches.
3. Panels are assumed to be in portrait orientation with a maximum length of 66"

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE-Lag Products

Table 1C		Roof Height: 0-30 ft						Rafter Species: Douglas Fir								
		Roof Angle: 8 - 26 degrees						Specific Gravity: 0.50								
Wind Load (Exposure Category B)																
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	qh	11.1	12.1	13.2	14.3	15.4	16.7	17.9	19.2	20.6	22.0	23.4	26.4	29.6	33.0	
	pg	ps	-7.6	-8.3	-9.1	-9.9	-10.7	-11.5	-12.4	-13.3	-14.2	-15.2	-16.1	-18.2	-20.4	-22.8
	0	0	126	126	126	126	126	123	117	112	107	103	99	93	87	81
	10	7.315	125	125	125	125	125	123	117	112	107	103	99	93	87	81
	20	14.63	98	98	98	98	98	98	98	98	98	98	98	93	87	81
	30	21.95	83	83	83	83	83	83	83	83	83	83	83	83	83	81
	40	29.26	73	73	73	73	73	73	73	73	73	73	73	73	73	73
	50	36.58	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	60	43.89	61	61	61	61	61	61	61	61	61	61	61	61	61	61
	70	51.21	57	57	57	57	57	57	57	57	57	57	57	57	57	57
	80	58.52	54	54	54	54	54	54	54	54	54	54	54	54	54	54
	100	73.15	48	48	48	48	48	48	48	48	48	48	48	48	48	48
	120	87.78	44	44	44	44	44	44	44	44	44	44	44	44	44	44

Notes:

1. Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and allowable uplift and lateral values of Quick Mount products per ICC reports.
2. Edge zone reductions are only required at shaded spans where reduction is 29 inches to a minimum of 32 inches.
3. Panels are assumed to be in portrait orientation with a maximum length of 66"

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE, QMSC, QMLC Products

Table 2A		Roof Height: 0-30 ft				Rafter Species: Douglas Fir				Roof Angle: 8 - 26 degrees				Specific Gravity: 0.50			
Wind Load (Exposure Category C)																	
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190		
	qh	15.48	16.92	18.42	19.99	21.62	23.32	25.08	26.9	28.79	30.74	32.75	36.98	41.46	46.19		
	pg	ps	-10.7	-11.7	-12.7	-13.8	-14.9	-16.1	-17.3	-18.6	-19.9	-21.2	-22.6	-25.5	-28.6	-31.9	
	0	0	126	121	115	109	104	100	95	92	88	85	82	76	72	68	
	10	7.315	125	121	115	109	104	100	95	92	88	85	82	76	72	68	
	20	14.63	98	98	98	98	98	98	95	92	88	85	82	76	72	68	
	30	21.95	83	83	83	83	83	83	83	83	83	83	82	76	72	68	
	40	29.26	73	73	73	73	73	73	73	73	73	73	73	73	72	68	
	50	36.58	66	66	66	66	66	66	66	66	66	66	66	66	66	66	
	60	43.89	61	61	61	61	61	61	61	61	61	61	61	61	61	61	
	70	51.21	57	57	57	57	57	57	57	57	57	57	57	57	57	57	
	80	58.52	54	54	54	54	54	54	54	54	54	54	54	54	54	54	
	100	73.15	48	48	48	48	48	48	48	48	48	48	48	48	48	48	
120	87.78	44	44	44	44	44	44	44	44	44	44	44	44	44	44		

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE, QMSC, QMLC Products

Table 2B		Roof Height: 0-30 ft				Rafter Species: Western Cedar				Roof Angle: 8 - 26 degrees				Specific Gravity: 0.36			
Wind Load (Exposure Category C)																	
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190		
	qh	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2		
	pg	ps	-10.7	-11.7	-12.7	-13.8	-14.9	-16.1	-17.3	-18.6	-19.9	-21.2	-22.6	-25.5	-28.6	-31.9	
	0	0	126	121	115	109	104	100	95	92	88	85	82	76	72	65	
	10	7.315	125	121	115	109	104	100	95	92	88	85	82	76	72	65	
	20	14.63	98	98	98	98	98	98	95	92	88	85	82	76	72	65	
	30	21.95	83	83	83	83	83	83	83	83	83	83	82	76	72	65	
	40	29.26	73	73	73	73	73	73	73	73	73	73	73	73	72	65	
	50	36.58	66	66	66	66	66	66	66	66	66	66	66	66	66	65	
	60	43.89	61	61	61	61	61	61	61	61	61	61	61	61	61	61	
	70	51.21	57	57	57	57	57	57	57	57	57	57	57	57	57	57	
	80	58.52	54	54	54	54	54	54	54	54	54	54	54	54	54	54	
	100	73.15	48	48	48	48	48	48	48	48	48	48	48	48	48	48	
120	87.78	44	44	44	44	44	44	44	44	44	44	44	44	44	44		

Notes:

1. Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and allowable uplift and lateral values of Quick Mount products per ICC reports.
2. Edge zone reductions are only required at shaded spans where reduction is 28 inches to a minimum of 32 inches.
3. Panels are assumed to be in portrait orientation with a maximum length of 66"

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE-Lag Products

Table 2C		Roof Height: 0-30 ft						Rafter Species: Douglas Fir								
		Roof Angle: 8 - 26 degrees						Specific Gravity: 0.50								
Wind Load (Exposure Category C)																
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	qh	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2	
	pg	ps	-10.7	-11.7	-12.7	-13.8	-14.9	-16.1	-17.3	-18.6	-19.9	-21.2	-22.6	-25.5	-28.6	-31.9
	0	0	126	121	115	109	104	100	95	92	88	85	82	76	72	68
	10	7.315	125	121	115	109	104	100	95	92	88	85	82	76	72	68
	20	14.63	98	98	98	98	98	98	95	92	88	85	82	76	72	68
	30	21.95	83	83	83	83	83	83	83	83	83	83	82	76	72	68
	40	29.26	73	73	73	73	73	73	73	73	73	73	73	73	72	68
	50	36.58	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	60	43.89	61	61	61	61	61	61	61	61	61	61	61	61	61	61
	70	51.21	57	57	57	57	57	57	57	57	57	57	57	57	57	57
	80	58.52	54	54	54	54	54	54	54	54	54	54	54	54	54	54
	100	73.15	48	48	48	48	48	48	48	48	48	48	48	48	48	48
	120	87.78	44	44	44	44	44	44	44	44	44	44	44	44	44	44

Notes:

1. Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and allowable uplift and lateral values of Quick Mount products per ICC reports.
2. Edge zone reductions are only required at shaded spans where reduction is 28 inches to a minimum of 32 inches.
3. Panels are assumed to be in portrait orientation with a maximum length of 66"

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE, QMSC, QMLC Products

Table 3A		Roof Height: 0-30 ft						Rafter Species: Douglas Fir								
		Roof Angle: 8 - 26 degrees						Specific Gravity: 0.50								
Wind Load (Exposure Category D)																
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	qh	18.33	20.03	21.81	23.66	25.59	27.6	29.68	31.84	34.08	36.39	38.77	43.77	49.07	54.67	
	pg	ps	-12.6	-13.8	-15	-16.3	-17.7	-19	-20.5	-22	-23.5	-25.1	-26.8	-30.2	-33.9	-37.7
	0	0	115	109	104	99	94	90	86	83	80	77	74	70	65	62
	10	7.315	115	109	104	99	94	90	86	83	80	77	74	70	65	62
	20	14.63	98	98	98	98	94	90	86	83	80	77	74	70	65	62
	30	21.95	83	83	83	83	83	83	83	83	80	77	74	70	65	62
	40	29.26	73	73	73	73	73	73	73	73	73	73	73	70	65	62
	50	36.58	66	66	66	66	66	66	66	66	66	66	66	66	65	62
	60	43.89	61	61	61	61	61	61	61	61	61	61	61	61	61	61
	70	51.21	57	57	57	57	57	57	57	57	57	57	57	57	57	57
	80	58.52	54	54	54	54	54	54	54	54	54	54	54	54	54	54
	100	73.15	48	48	48	48	48	48	48	48	48	48	48	48	48	48
	120	87.78	44	44	44	44	44	44	44	44	44	44	44	44	44	44

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE, QMSC, QMLC Products

Table 3B		Roof Height: 0-30 ft						Rafter Species: Western Cedar								
		Roof Angle: 8 - 26 degrees						Specific Gravity: 0.36								
Wind Load (Exposure Category D)																
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	qh	18.3	20.0	21.8	23.7	25.6	27.6	29.7	31.8	34.1	36.4	38.8	43.8	49.1	54.7	
	pg	ps	-12.6	-13.8	-15.0	-16.3	-17.7	-19.0	-20.5	-22.0	-23.5	-25.1	-26.8	-30.2	-33.9	-37.7
	0	0	115	109	104	99	94	90	86	83	80	77	74	68	60	54
	10	7.315	115	109	104	99	94	90	86	83	80	77	74	68	60	54
	20	14.63	98	98	98	98	94	90	86	83	80	77	74	68	60	54
	30	21.95	83	83	83	83	83	83	83	83	80	77	74	68	60	54
	40	29.26	73	73	73	73	73	73	73	73	73	73	73	68	60	54
	50	36.58	66	66	66	66	66	66	66	66	66	66	66	66	60	54
	60	43.89	61	61	61	61	61	61	61	61	61	61	61	61	60	54
	70	51.21	57	57	57	57	57	57	57	57	57	57	57	57	57	54
	80	58.52	54	54	54	54	54	54	54	54	54	54	54	54	54	54
	100	73.15	48	48	48	48	48	48	48	48	48	48	48	48	48	48
	120	87.78	44	44	44	44	44	44	44	44	44	44	44	44	44	44

Notes:

1. Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and allowable uplift and lateral values of Quick Mount products per ICC reports.
2. Edge zone reductions are only required at shaded spans where reduction is 26 inches to a minimum of 32 inches.
3. Panels are assumed to be in portrait orientation with a maximum length of 66"

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE-Lag Products

Table 3C		Roof Height: 0-30 ft				Rafter Species: Douglas Fir				Roof Angle: 8 - 26 degrees				Specific Gravity: 0.50			
Wind Load (Exposure Category D)																	
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190		
	qh	18.3	20.0	21.8	23.7	25.6	27.6	29.7	31.8	34.1	36.4	38.8	43.8	49.1	54.7		
	pg	ps	-12.6	-13.8	-15.0	-16.3	-17.7	-19.0	-20.5	-22.0	-23.5	-25.1	-26.8	-30.2	-33.9	-37.7	
	0	0	115	109	104	99	94	90	86	83	80	77	74	70	65	62	
	10	7.315	115	109	104	99	94	90	86	83	80	77	74	70	65	62	
	20	14.63	98	98	98	98	94	90	86	83	80	77	74	70	65	62	
	30	21.95	83	83	83	83	83	83	83	83	80	77	74	70	65	62	
	40	29.26	73	73	73	73	73	73	73	73	73	73	73	70	65	62	
	50	36.58	66	66	66	66	66	66	66	66	66	66	66	66	65	62	
	60	43.89	61	61	61	61	61	61	61	61	61	61	61	61	61	61	
	70	51.21	57	57	57	57	57	57	57	57	57	57	57	57	57	57	
	80	58.52	54	54	54	54	54	54	54	54	54	54	54	54	54	54	
	100	73.15	48	48	48	48	48	48	48	48	48	48	48	48	48	48	
120	87.78	44	44	44	44	44	44	44	44	44	44	44	44	44	44		

Notes:

1. Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and allowable uplift and lateral values of Quick Mount products per ICC reports.
2. Edge zone reductions are only required at shaded spans where reduction is 26 inches to a minimum of 32 inches.
3. Panels are assumed to be in portrait orientation with a maximum length of 66"

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE, QMSC, QMLC Products

Table 4A		Roof Height:		0-30 ft								Rafter Species:		Douglas Fir			
		Roof Angle:		27 - 45 degrees								Specific Gravity:		0.50			
Wind Load (Exposure Category B)																	
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190		
	qh	11.06	12.09	13.16	14.28	15.45	16.66	17.91	19.22	20.56	21.96	23.4	26.41	29.61	32.99		
	pg	ps	-4.76	-5.2	-5.66	-6.14	-6.64	-7.16	-7.7	-8.26	-8.84	-9.44	-10.1	-11.4	-12.7	-14.2	
	0	0	126	126	126	126	126	126	126	126	126	126	126	123	115	107	
	10	5.39	126	126	126	126	126	126	126	126	125	124	123	120	115	107	
	20	10.78	109	109	109	109	109	109	109	108	108	107	106	105	103	101	
	30	16.17	94	94	94	94	94	94	94	94	94	94	94	94	93	91	
	40	21.56	84	84	84	84	84	84	84	84	84	84	84	84	84	84	
	50	26.95	76	76	76	76	76	76	76	76	76	76	76	76	76	76	
	60	32.34	70	70	70	70	70	70	70	70	70	70	70	70	70	70	
	70	37.73	66	66	66	66	66	66	66	66	66	66	66	66	66	66	
	80	43.12	62	62	62	62	62	62	62	62	62	62	62	62	62	62	
	100	53.9	56	56	56	56	56	56	56	56	56	56	56	56	56	56	
120	64.68	51	51	51	51	51	51	51	51	51	51	51	51	51	51		

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE, QMSC, QMLC Products

Table 4B		Roof Height:		0-30 ft								Rafter Species:		Western Cedar			
		Roof Angle:		27 - 45 degrees								Specific Gravity:		0.36			
Wind Load (Exposure Category B)																	
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190		
	qh	11.1	12.1	13.2	14.3	15.4	16.7	17.9	19.2	20.6	22.0	23.4	26.4	29.6	33.0		
	pg	ps	-4.8	-5.2	-5.7	-6.1	-6.6	-7.2	-7.7	-8.3	-8.8	-9.4	-10.1	-11.4	-12.7	-14.2	
	0	0	126	126	126	126	126	126	126	126	126	126	126	123	115	107	
	10	5.39	126	126	126	126	126	126	126	126	125	124	123	120	115	107	
	20	10.78	109	109	109	109	109	109	109	108	108	107	106	105	103	101	
	30	16.17	94	94	94	94	94	94	94	94	94	94	94	94	93	91	
	40	21.56	84	84	84	84	84	84	84	84	84	84	84	84	84	84	
	50	26.95	76	76	76	76	76	76	76	76	76	76	76	76	76	76	
	60	32.34	70	70	70	70	70	70	70	70	70	70	70	70	70	70	
	70	37.73	66	66	66	66	66	66	66	66	66	66	66	66	66	66	
	80	43.12	62	62	62	62	62	62	62	62	62	62	62	62	62	62	
	100	53.9	56	56	56	56	56	56	56	56	56	56	56	56	56	56	
120	64.68	51	51	51	51	51	51	51	51	51	51	51	51	51	51		

Notes:

1. Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and allowable uplift and lateral values of Quick Mount products per ICC reports.
2. Edge zone reductions are only required at shaded spans where reduction is 15 inches to a minimum of 32 inches.
3. Panels are assumed to be in portrait orientation with a maximum length of 66"

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE-Lag Products

Table 4C		Roof Height:		0-30 ft		Rafter Species:		Douglas Fir								
		Roof Angle:		27 - 45 degrees		Specific Gravity:		0.50								
Wind Load (Exposure Category B)																
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	qh	11.1	12.1	13.2	14.3	15.4	16.7	17.9	19.2	20.6	22.0	23.4	26.4	29.6	33.0	
	pg	ps	-4.8	-5.2	-5.7	-6.1	-6.6	-7.2	-7.7	-8.3	-8.8	-9.4	-10.1	-11.4	-12.7	-14.2
	0	0	126	126	126	126	126	126	126	126	126	126	126	123	115	107
	10	5.39	126	126	126	126	126	126	126	126	125	124	123	120	115	107
	20	10.78	109	109	109	109	109	109	109	108	108	107	106	105	103	101
	30	16.17	94	94	94	94	94	94	94	94	94	94	94	94	93	91
	40	21.56	84	84	84	84	84	84	84	84	84	84	84	84	84	84
	50	26.95	76	76	76	76	76	76	76	76	76	76	76	76	76	76
	60	32.34	70	70	70	70	70	70	70	70	70	70	70	70	70	70
	70	37.73	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	80	43.12	62	62	62	62	62	62	62	62	62	62	62	62	62	62
	100	53.9	56	56	56	56	56	56	56	56	56	56	56	56	56	56
	120	64.68	51	51	51	51	51	51	51	51	51	51	51	51	51	51

Notes:

1. Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and allowable uplift and lateral values of Quick Mount products per ICC reports.
2. Edge zone reductions are only required at shaded spans where reduction is 15 inches to a minimum of 32 inches.
3. Panels are assumed to be in portrait orientation with a maximum length of 66"

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE, QMSC, QMLC Products

Table 5A		Roof Height: 0-30 ft				Rafter Species: Douglas Fir				Roof Angle: 27 - 45 degrees				Specific Gravity: 0.50			
Wind Load (Exposure Category C)																	
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190		
	qh	15.48	16.92	18.42	19.99	21.62	23.32	25.08	26.9	28.79	30.74	32.75	36.98	41.46	46.19		
	pg	ps	-6.66	-7.28	-7.92	-8.6	-9.3	-10	-10.8	-11.6	-12.4	-13.2	-14.1	-15.9	-17.8	-19.9	
	0	0	126	126	126	126	126	126	126	122	117	112	108	100	94	88	
	10	5.39	126	126	126	125	124	123	121	120	117	112	108	100	94	88	
	20	10.78	109	109	109	108	107	106	105	104	103	102	102	100	94	88	
	30	16.17	94	94	94	94	94	94	94	94	93	92	91	90	89	87	
	40	21.56	84	84	84	84	84	84	84	84	84	84	84	83	82	81	
	50	26.95	76	76	76	76	76	76	76	76	76	76	76	76	76	75	
	60	32.34	70	70	70	70	70	70	70	70	70	70	70	70	70	70	
	70	37.73	66	66	66	66	66	66	66	66	66	66	66	66	66	66	
	80	43.12	62	62	62	62	62	62	62	62	62	62	62	62	62	62	
	100	53.9	56	56	56	56	56	56	56	56	56	56	56	56	56	56	
120	64.68	51	51	51	51	51	51	51	51	51	51	51	51	51	51		

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE, QMSC, QMLC Products

Table 5B		Roof Height: 0-30 ft				Rafter Species: Western Cedar				Roof Angle: 27 - 45 degrees				Specific Gravity: 0.36			
Wind Load (Exposure Category C)																	
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190		
	qh	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2		
	pg	ps	-6.7	-7.3	-7.9	-8.6	-9.3	-10.0	-10.8	-11.6	-12.4	-13.2	-14.1	-15.9	-17.8	-19.9	
	0	0	126	126	126	126	126	126	126	122	117	112	108	100	94	88	
	10	5.39	126	126	126	125	124	123	121	120	117	112	108	100	94	88	
	20	10.78	109	109	109	108	107	106	105	104	103	102	102	100	94	88	
	30	16.17	94	94	94	94	94	94	94	94	93	92	91	90	89	87	
	40	21.56	84	84	84	84	84	84	84	84	84	84	84	83	82	81	
	50	26.95	76	76	76	76	76	76	76	76	76	76	76	76	76	75	
	60	32.34	70	70	70	70	70	70	70	70	70	70	70	70	70	70	
	70	37.73	66	66	66	66	66	66	66	66	66	66	66	66	66	66	
	80	43.12	62	62	62	62	62	62	62	62	62	62	62	62	62	62	
	100	53.9	56	56	56	56	56	56	56	56	56	56	56	56	56	56	
120	64.68	51	51	51	51	51	51	51	51	51	51	51	51	51	51		

Notes:

1. Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and allowable uplift and lateral values of Quick Mount products per ICC reports.
2. Edge zone reductions are only required at shaded spans where reduction is 15 inches to a minimum of 32 inches.
3. Panels are assumed to be in portrait orientation with a maximum length of 66"

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE-Lag Products

Table 5C		Roof Height: 0-30 ft						Rafter Species: Douglas Fir								
		Roof Angle: 27 - 45 degrees						Specific Gravity: 0.50								
Wind Load (Exposure Category C)																
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	qh	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2	
	pg	ps	-6.7	-7.3	-7.9	-8.6	-9.3	-10.0	-10.8	-11.6	-12.4	-13.2	-14.1	-15.9	-17.8	-19.9
	0	0	126	126	126	126	126	126	126	122	117	112	108	100	94	88
	10	5.39	126	126	126	125	124	123	121	120	117	112	108	100	94	88
	20	10.78	109	109	109	108	107	106	105	104	103	102	102	100	94	88
	30	16.17	94	94	94	94	94	94	94	94	93	92	91	90	89	87
	40	21.56	84	84	84	84	84	84	84	84	84	84	84	83	82	81
	50	26.95	76	76	76	76	76	76	76	76	76	76	76	76	76	75
	60	32.34	70	70	70	70	70	70	70	70	70	70	70	70	70	70
	70	37.73	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	80	43.12	62	62	62	62	62	62	62	62	62	62	62	62	62	62
	100	53.9	56	56	56	56	56	56	56	56	56	56	56	56	56	56
120	64.68	47	47	47	47	47	47	47	47	47	47	47	47	47	47	

Notes:

1. Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and allowable uplift and lateral values of Quick Mount products per ICC reports.
2. Edge zone reductions are only required at shaded spans where reduction is 15 inches to a minimum of 32 inches.
3. Panels are assumed to be in portrait orientation with a maximum length of 66"

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE, QMSC, QMLC Products

Table 6A		Roof Height: 0-30 ft				Rafter Species: Douglas Fir				Roof Angle: 27 - 45 degrees				Specific Gravity: 0.50			
Wind Load (Exposure Category D)																	
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190		
	qh	18.33	20.03	21.81	23.66	25.59	27.6	29.68	31.84	34.08	36.39	38.77	43.77	49.07	54.67		
	pg	ps	-7.88	-8.61	-9.38	-10.2	-11	-11.9	-12.8	-13.7	-14.7	-15.6	-16.7	-18.8	-21.1	-23.5	
	0	0	126	126	126	126	126	120	115	110	105	101	97	91	85	80	
	10	5.39	126	125	124	122	121	119	115	110	105	101	97	91	85	80	
	20	10.78	109	108	107	106	105	104	103	102	101	100	97	91	85	80	
	30	16.17	94	94	94	94	94	93	93	92	91	90	90	88	85	80	
	40	21.56	84	84	84	84	84	84	84	84	84	83	82	81	80	79	
	50	26.95	76	76	76	76	76	76	76	76	76	76	76	76	75	74	
	60	32.34	70	70	70	70	70	70	70	70	70	70	70	70	70	70	
	70	37.73	66	66	66	66	66	66	66	66	66	66	66	66	66	66	
	80	43.12	62	62	62	62	62	62	62	62	62	62	62	62	62	62	
	100	53.9	56	56	56	56	56	56	56	56	56	56	56	56	56	56	
120	64.68	51	51	51	51	51	51	51	51	51	51	51	51	51	51		

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE, QMSC, QMLC Products

Table 6B		Roof Height: 0-30 ft				Rafter Species: Western Cedar				Roof Angle: 27 - 45 degrees				Specific Gravity: 0.36			
Wind Load (Exposure Category D)																	
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190		
	qh	18.3	20.0	21.8	23.7	25.6	27.6	29.7	31.8	34.1	36.4	38.8	43.8	49.1	54.7		
	pg	ps	-7.9	-8.6	-9.4	-10.2	-11.0	-11.9	-12.8	-13.7	-14.7	-15.6	-16.7	-18.8	-21.1	-23.5	
	0	0	126	126	126	126	126	120	115	110	105	101	97	91	85	80	
	10	5.39	126	125	124	122	121	119	115	110	105	101	97	91	85	80	
	20	10.78	109	108	107	106	105	104	103	102	101	100	97	91	85	80	
	30	16.17	94	94	94	94	94	93	93	92	91	90	90	88	85	80	
	40	21.56	84	84	84	84	84	84	84	84	84	83	82	81	80	79	
	50	26.95	76	76	76	76	76	76	76	76	76	76	76	76	75	74	
	60	32.34	70	70	70	70	70	70	70	70	70	70	70	70	70	70	
	70	37.73	66	66	66	66	66	66	66	66	66	66	66	66	66	66	
	80	43.12	62	62	62	62	62	62	62	62	62	62	62	62	62	62	
	100	53.9	56	56	56	56	56	56	56	56	56	56	56	56	56	56	
120	64.68	51	51	51	51	51	51	51	51	51	51	51	51	51	51		

Notes:

1. Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and allowable uplift and lateral values of Quick Mount products per ICC reports.
2. Edge zone reductions are only required at shaded spans where reduction is 16 inches to a minimum of 32 inches.
3. Panels are assumed to be in portrait orientation with a maximum length of 66"

Rail Spans for SnapNrack Series 100 Roof Mount for use with QMSE-Lag Products

Table 6C		Roof Height:		0-30 ft		Rafter Species:		Douglas Fir								
		Roof Angle:		27 - 45 degrees		Specific Gravity:		0.50								
Wind Load (Exposure Category D)																
Ground Snow Load (psf)	vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	qh	18.3	20.0	21.8	23.7	25.6	27.6	29.7	31.8	34.1	36.4	38.8	43.8	49.1	54.7	
	pg	ps	-7.9	-8.6	-9.4	-10.2	-11.0	-11.9	-12.8	-13.7	-14.7	-15.6	-16.7	-18.8	-21.1	-23.5
	0	0	126	126	126	126	126	120	115	110	105	101	97	91	85	80
	10	5.39	126	125	124	122	121	119	115	110	105	101	97	91	85	80
	20	10.78	109	108	107	106	105	104	103	102	101	100	97	91	85	80
	30	16.17	94	94	94	94	94	93	93	92	91	90	90	88	85	80
	40	21.56	84	84	84	84	84	84	84	84	84	83	82	81	80	79
	50	26.95	76	76	76	76	76	76	76	76	76	76	76	76	75	74
	60	32.34	70	70	70	70	70	70	70	70	70	70	70	70	70	70
	70	37.73	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	80	43.12	62	62	62	62	62	62	62	62	62	62	62	62	62	62
	100	53.9	56	56	56	56	56	56	56	56	56	56	56	56	56	56
	120	64.68	47	47	47	47	47	47	47	47	47	47	47	47	47	47

Notes:

1. Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and allowable uplift and lateral values of Quick Mount products per ICC reports.
2. Edge zone reductions are only required at shaded spans where reduction is 16 inches to a minimum of 32 inches.
3. Panels are assumed to be in portrait orientation with a maximum length of 66"