

# Certificate of Compliance

Certificate Number 20150106-E361971  
Report Reference E361971-20140619  
Issue Date 2015 January 6

Page 1 of 1



*Issued to:* QUICK MOUNT PV

Bldg 2  
2700 Mitchell Dr  
Walnut Creek, CA 94598

*This is to certify that  
representative samples of*

**MOUNTING SYSTEMS, MOUNTING DEVICES,  
Quick Rack**

*Have been investigated by UL LLC in accordance with the Standard(s)  
indicated on this Certificate.*


*Standard(s) for Safety:*

UL 2703, Mounting Systems, Mounting Devices, Clamping/Retention Devices,  
and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels.

*Additional Information:*

See UL On-line Certification Directory at [WWW.UL.COM](http://www.ul.com) for additional information.  
The Quick Rack system achieved a system fire classification 'A' when tested in  
combination with UL1703 Listed Type 1 rated PV module. The system fire test method  
was in accordance to Standard For Safety For Flat-Plate Photovoltaic Modules and Panels,  
UL 1703, 3<sup>rd</sup> Edition, dated May 20, 2014.

**Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.**

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

**William R. Carney**  
**Director, North American Certification Programs**

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.



For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>



3933 US Route 11  
Cortland, NY 13045 USA  
Telephone: 607-758-6559  
www.intertek.com

# Test Verification of Conformity

In the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.

<b>Applicant Name &amp; Address:</b>	Wencon Development, Inc. 2700 Mitchell Drive, Building 2 Walnut Creek, CA 94598	
<b>Product Description:</b>	Photovoltaic Roof Mount System.	
<b>Ratings &amp; Principle Characteristics:</b>	<u>Fire Class Resistance Rating:</u> - Class A for Steep Slope applications when using Type 2, listed photovoltaic modules and a Fire Rated roof. Testing was conducted with a 5" gap between the module and the roof surface. The use of a wind deflector is optional.	
<b>Models:</b>	QuickRack PV mounting System	
<b>Brand Name:</b>	Wencon	
<b>Relevant Standards:</b>	UL Subject 2703 (Section 15.2 and 15.3) Outline of Investigation for Rack Mounting Systems and Clamping Devices for Flat-Plate Photovoltaic Modules and Panels, First Edition, January 28, 2015 <b>Referencing</b> UL1703 Third Edition(Section 31.2) Standard for Safety for Flat-Plate Photovoltaic Modules and Panels, Oct. 2015.	
<b>Verification Issuing Office:</b>	Intertek Testing Services NA, Inc. 8431 Murphy Drive Middleton, WI 53562 USA	
<b>Date of Tests:</b>	10/01/2015-10/02/2015	
<b>Test Report Number(s):</b>	102284461MID-001	
<p><b>This verification is part of the full test report(s) and should be read in conjunction with them. This report does not automatically imply product certification.</b></p>		
<b>Completed by:</b>	Christopher Zimbrich	<b>Reviewed by:</b> Gregory Allen
<b>Title:</b>	Technician II, Fire Resistance	<b>Title:</b> Engineering Team Lead, Fire Resistance
<b>Signature:</b>		<b>Signature:</b> 
<b>Date:</b>	10/30/2015	<b>Date:</b> 10/30/2015

*This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.*